

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7125-0067:238 Page 1 of 1

**CATEGORY:** Fire Alarm Devices for the Hearing Impaired

**LISTEE:** Siemens Building Technologies/Fire Safety Division, 8 Fernwood Rd, Florham Park NJ 07932  
Contact: Peter Pawchak (973) 593-2662 FAX (973) 593-6652

**DESIGN:** Models U-S17-AC, U-S30-AC, U-S60-AC, U-S75-AC, U-S110-AC, U-S17-6090V-AC, U-S30-6090V-AC, U-S60-6090V-AC, U-S75-6090V-AC, and U-S110-6090V-AC followed by -W or -C selectable candela, synchronizable strobes. For use in synchronized or non-synchronized circuits. Strobes used in synchronized circuits must be used with Models SCM-F, SCM-FW, DSC, and DSC-W Sync Modules. Refer to the listee's data sheet for detailed product description and operational considerations.

**RATING:** Electrical: 20-31 VDC; 120 VAC, 16-33 VDC/FWR  
  
Selectable Candela: 15cd, 30cd, 75cd, or 110cd  
  
Flash Rate: 60 flashes/min

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating, and UL label.

**APPROVAL:** Listed as selectable type synchronized strobe lights suitable for the hearing impaired when used in conjunction with separately listed compatible audible signal devices and fire alarm control units. All units are suitable for wall or ceiling mounted. For indoor use only. Refer to listee's Installation Instruction Manual for details.

**XLF:** 7125-0065:154

06-19-03KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 18, 2004**

*Listing Expires **June 30, 2005***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager